HEARTWOOD SOLAR INTERCONNECTION INFORMATION

The Project will interconnect to the MISO transmission system at the METC-owned Coldwater to Moore Rd 138kV transmission line (POI). The POI is within the MISO Planning Zone 7 for energy and reserves. Heartwood Solar has applied for Network Resource Interconnection Service for the full 150 MW output. Preliminary load flow work shows the location can accommodate 150 MW of generation with network upgrades.

Heartwood Solar has established the queue position J1658 in the MISO Interconnection Queue and is in the DPP-2020-East-ITC Cluster. A Generator Interconnection Agreement (GIA) is expected for Heartwood Solar in January 2023.